

Certificate

No. SEBS-A.104701/18 V 1.0

TUV NORD Systems GmbH & Co. KG hereby certifies to

ReeR S.p.a.

Via Carcano 32
10153 Torino
Italy

that the inductive proximity switches

**PI M12 NF, PI M18 NF, PI M18 F,
PI M30 NF, PI M30 F and PI M18 F R**

meets the requirements listed in the below mentioned standards

- IEC 61508: 2010; SIL 2
- ISO 13849-1:2015; PL d
- IEC 62061:2005 + AMD1:2012 + AMD2:2015; SILcl 2
- IEC 60947-5-3: 2013

Certification program Leittechnik (SEB-ZE-SEECERT-VA-320-20, Rev. 3/9.15)

Base of certification is the report
SEBS-A.104701/18TB in the valid
version.

This certificate entitles the holder to
use the pictured safety approved mark.

Valid until: 2024-01-11

File reference: 8116316222

Hamburg, 2019-01-11


Bianca Pfuff

